

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7125-0065:169 Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** Faraday Inc., 805 S. Maumee St., Tecumseh, MI 49286  
Contact: Steven A. Blohm (517) 423-2111

**DESIGN:** Models 2700 and 2701 selectable candela, synchronizable strobes. For use in synchronized or non-synchronized circuits. \*Strobes used in synchronized circuits must be used with models 5405 or 5406 sync module, or any other source providing the Faraday sync protocol. Refer to listee's data sheet for additional detailed product description, electrical rating and operational considerations.

**RATING:** Electrical: 16-33 VDC/FWR  
  
Selectable Candela: 15cd, 30cd, 75cd or 110cd  
  
Flash Rate: 60 flashes/min

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For wall and ceiling mount and indoor use only.

**MARKING:** Listee's name or "FOS", model number, electrical rating and UL label.

**APPROVAL:** Listed as selectable type synchronizable strobe lights for the hearing impaired when used in conjunction with separately listed compatible with fire alarm control units. All units are suitable for wall or ceiling mounted. For indoor use only.

\*Corrected 07-26-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager